



Certificate of Completion

Duct Sealing Performed For:

Lertora, karen
10760 Mist Haven Terrace
Rockville, MD 20852

Overall Sealing Results

When we arrived,
YOUR DUCTS HAD:

449.2 CFM of Leakage, equivalent to a
84.9 Square Inch Hole


This equals 269.5 refrigerators full of air loss every hour.

After we finished,
YOUR DUCTS HAVE:

10.6 CFM of Leakage, equivalent to a
2.0 Square Inch Hole

This corresponds to a **97.6% Reduction in Duct Leakage.**

Note: Duct Leakage results are calculated in Cubic Feet per Minute (CFM) measured at a standard OPERATING PRESSURE of 25 Pa.



Aeroseal Technician **Brian**

Aeroseal Case ID **4174**

Date of Seal **9/27/2017**

System Description **forced air**

Seal Description **whole home**

Hardware **HomeSeal**

AEROSEAL[®]
Duct Sealing From The Inside

Duct Sealing Performed By:

James A. Wheat & Sons, Inc.
7834 Beechcraft Ave.
Gaithersburg, MD 20879
Phone: 301-670-1944